

Other Options

[Return to menu](#)
[Plot this site in State Library Digital Atlas](#)
[Plot this site in Google Maps](#)

Section 7: Well Test Data

Total Depth: 260
Static Water Level: 120
Water Temperature:

Air Test *

20 gpm with drill stem set at 255 feet for 2 hours.
Time of recovery 2 hours.
Recovery water level 120 feet.
Pumping water level _ feet.

** During the well test the discharge rate shall be as uniform as possible. This rate may or may not be the sustainable yield of the well. Sustainable yield does not include the reservoir of the well casing.*

Section 8: Remarks

Section 9: Well Log

Geologic Source

400BELT - BELT SUPERGROUP

[illegible]

Driller Certification

All work performed and reported in this well log is in compliance with the Montana well construction standards. This report is true to the best of my knowledge.

Name: JOE LISS
Company: JOE LISS WATER WELLS, INC.
License No: WWC-625
Date Completed: 8/15/2015

Borehole dimensions

Casing

Completion (Perf/Screen)

Annular Space (Seal/Grout/Packer)

1/1